

Rotary actuator for ball valves

- Nominal torque 4 Nm
- Nominal voltage AC/DC 24 V
- Control Open-close
- · Running time motor 9 s



Technical data				
Electrical data	Nominal voltage	AC/DC 24 V		
	Nominal voltage frequency	50/60 Hz		
	Nominal voltage range	AC 19.228.8 V / DC 19.228.8 V		
	Power consumption in operation	13 W		
	Power consumption in rest position	2 W		
	Power consumption for wire sizing	23 VA		
	Power consumption for wire sizing note	Imax 20 A @ 5 ms		
	Connection supply / control	Cable 1 m, 3 x 0.75 mm ²		
	Parallel operation	Yes (note the performance data)		
Functional data	Torque motor	Min. 4 Nm		
	Manual override	Gear disengagement with push-button, can be		
		locked		
	Running time motor	9 s / 90°		
	Adaption setting range	manual (automatic on first power-up)		
	Sound power level motor	45 dB(A)		
	Position indication	Mechanically, pluggable		
Safety	Protection class IEC/EN	III Safety extra-low voltage		
	Protection class UL	UL Class 2 Supply		
	Degree of protection IEC/EN	IP54		
	Degree of protection NEMA/UL	NEMA 2, UL Enclosure Type 2		
	EMC	CE according to 2004/108/EC		
	Certification IEC/EN	IEC/EN 60730-1 and IEC/EN 60730-2-14		
Certification UL		cULus according to UL 60730-1A, UL 60730-2-		
		14 and CAN/CSA E60730-1:02		
	Mode of operation	Type 1		
	Rated impulse voltage supply / control	0.8 kV		
	Control pollution degree	3		
	Ambient temperature	-3040°C		
	Ambient temperature note	Caution: +40+50°C utilisation possible only		
		under certain restrictions. Please contact your		
	Non-anaustina tamanaustura	supplier.		
	Non-operating temperature	-4080°C		
	Ambient humidity	95% r.h., non-condensing		
	Maintenance	Maintenance-free		

Safety notes



Weight

Weight approx.

 This device has been designed for use in stationary heating, ventilation and air conditioning systems and is not allowed to be used outside the specified field of application, especially in aircraft or in any other airborne means of transport.

0.92 kg

- Only authorised specialists may carry out installation. All applicable legal or institutional installation regulations must be complied during installation.
- The switch for changing the direction of rotation may only be operated by authorised specialists. The direction of rotation must not in particular be reversed in a frost protection circuit.
- The device may only be opened at the manufacturer's site. It does not contain any parts that can be replaced or repaired by the user.



Safety notes

- · Cables must not be removed from the device.
- Self adaption is necessary when the system is commissioned and after each adjustment of the angle of rotation (press the adaption push-button once).
- The device contains electrical and electronic components and is not allowed to be disposed of as household refuse. All locally valid regulations and requirements must be observed.

Product features

Simple direct mounting

Straightforward direct mounting on the ball valve with only one central screw. The assembly tool is integrated in the plug-in position indication. The mounting orientation in relation to the ball valve can be selected in 90° steps.

Manual override

Manual override with push-button possible (the gear is disengaged for as long as the button is pressed or remains locked).

High functional reliability

The actuator is overload protected, requires no limit switches and automatically stops when the end stop is reached.

Adjustable angle of rotation

Adjustable angle of rotation with mechanical end stops.

Home position

The first time the supply voltage is switched on, i.e. at the time of commissioning, the actuator carries out an adaption, which is when the operating range and position feedback adjust themselves to the mechanical setting range.

The detection of the mechanical end stops enables a gentle approach to the end positions, thus protecting the actuator mechanics.

The actuator then moves into the position defined by the positioning signal.

Factory setting: Y2 (counter-clockwise rotation).

Adaption and synchronisation

An adaption can be triggered manually by pressing the "Adaption" button. Both mechanical end stops are detected during the adaption (entire setting range). Automatic synchronisation after pressing the gearbox disengagement button is configured. The synchronisation is in the home position (0%).

The actuator then moves into the position defined by the positioning signal.

Accessories

Flectrical	accessories
Licuitai	accessories

Description	Туре
Auxiliary switch, add-on, 1 x SPDT	S1A
Auxiliary switch, add-on, 2 x SPDT	S2A
Feedback potentiometer 140 Ohm, add-on	P140A
Feedback potentiometer 200 Ohm, add-on	P200A
Feedback potentiometer 500 Ohm, add-on	P500A
Feedback potentiometer 1 kOhm, add-on	P1000A
Feedback potentiometer 2.8 kOhm, add-on	P2800A
Feedback potentiometer 5 kOhm, add-on	P5000A
Feedback potentiometer 10 kOhm, add-on	P10000A



Electrical installation




Notes

- · Connection via safety isolating transformer.
- Parallel connection of other actuators possible. Observe the performance data.
- Direction of rotation switch is covered. Factory setting: Direction of rotation Y2.

Wiring diagrams


AC/DC 24 V, open-close



Cable colours:

- 1 = black
- 2 = red
- 3 = white

Operating controls and indicators



Direction of rotation switch

Switch over: Direction of rotation changes

2 Push-button and LED display green

Off: No power supply or malfunction

On: In operation

Press button: Triggers angle of rotation adaptation, followed by standard mode

3 Push-button and LED display yellow

Off: Standard mode

On: Adaptation or synchronising process active

Press button: No function

4 Gear disengagement button

Press button: Gear disengages, motor stops, manual override possible

Release button: Gear engages, synchronisation starts, followed by standard mode


Check power supply connection


2 Off and 3 On Possible wiring error in power supply



Dimensions [mm]

Dimensional drawings





Further documentation

- · Overview Valve-actuator combinations
- Data sheets for ball valves
- · Installation instructions for actuators and/or ball valves
- · General notes for project planning